PUBLIC UTILITIES DEPARTMENT
ENVIRONMENTAL MONITORING AND TECHNICAL SERVICES

South Bay Water Reclamation Plant (SBWRP)
Horticultural and Industrial Users Recycled Water Quality Report

MAY 2013

	Symbol	Unit of Measurement	Recycled Water Permit Limit[3]	SBWRP Recycled Water
Alkalinity	$CaCO_3$	mg/L	-------	194
Hydrogen Ion Activity	pH	Units	6.0 -9.0	7.47
Electrical Conductivity	ECw	umhos/cm	-------	1640
Total Dissolved Solids	TDS	mg/L	1,200	1070
Calcium	Ca	mg/L	-------	69
Magnesium	Mg	mg/L	-------	33
Potassium	K	mg/L	-------	18
Sodium	Na	mg/L	-------	212
Sulfate	S	mg/L	-------	169
Iron	Fe	mg/L	0.3	.09
Zinc	Zn	mg/L	-------	.039
Manganese	Mn	mg/L	0.05	.0085
Boron	B	mg/L	0.7	.33
Ammonia - Nitrogen	NH_3-N	mg/L	-------	ND
Nitrate	NO_3	mg/L	-------	34
Total Nitrogen (Actual)	N	mg/L	-------	9.02
Phosphorus	P	mg/L	-------	1.16
Chloride	Cl	mg/L	300	271
Total Nitrogen (Actual)	N	lbs/ acre ft[4]	-------	24.5
Phosphorus Pentoxide[1]	P_2O_5	lbs/ acre ft[4]	-------	7.25
Potassium Oxide[2]	K_2O	lbs/ acre ft[4]	-------	58.7
Residual Sodium Carbonate	RSC	meq/L	<1.25	-2.28
Adjusted Sodium Adsoprtion Ratio	SAR	Calculated	6	5.9

[1]Determined as Phosphorus in the elemental form (P); Phosphorus Pentoxide (P_2O_5) calculated by multiplying P by 2.3.
[2]Determined as Potassium in the elemental form (K); Potassium Oxide (K_2O) calculated by multiply K by 1.2.
[3] SDRWQCB Order #97-03
[4]This value is presented in lbs/acre-ft of water applied 1 mg/L = 2.719 lbs/ac ft
* 1mg/L = 1ppm
-------- = No Permit Limits